Penetration & Linear Gap Seals Scheme

Certificate Number: IFCC 1827

Certificate

Initial Certification: 09 March 2023
Valid to: 08 March 2028

Revised: 18 December 2025
Issue No: 3

Issued by **IFC Certification Ltd** part of the Kiwa UK Group

This is to certify that

Fischerwerke GmbH & Co KG

Klaus-Fischer-Strasse 1
Waldachtal
Germany
72178
Tel: +49 151 571 287 05

Who fabricate the following system:

Fischer VentiStop Open State Cavity Barrier FFB-VS

have satisfied the requirements of the Penetrations and Linear Gap Seals scheme SDP 13 v1.4. This includes the testing of products to EN1363-1:2012 in conjunction with ASFP TGD19, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and test reports to achieve from **30 minutes to 120 minutes integrity and insulation** are detailed on page 2 of this certificate.

David Mowatt
Head of IFC Certification /
Kiwa UK

kiwa CERTIFIED Product Scheme IFC Certification

UKAS PRODUCT CERTIFICATION 0175

Certificate is only valid if verified on the website.
Check the validity of this certificate by scanning this QR Code or visiting www.ifccertification.com/search/

KIWA
IFC Certification Ltd
Ground Floor, Suite A
Building 2,
Bear Brook Office Park
Walton Street, Aylesbury,
Bucks, HP21 7GQ

Certificate

The production of cavity barriers are manufactured in accordance with the assessment/ test reports referenced within the following tables:

Test Report	Specimen	Overall width (mm)	Cavity width (mm)	Integrity (mins)	Insulation (mins)
4788805638	A	150	175	111	54
	B	325	350	75	49
	C	125	175	105	37

Test Report	Specimen	Overall width (mm)	Cavity width (mm)	Integrity (mins)	Insulation (mins)
4788937151	A	150	175	132	123
	B	325	350	132	64
	C	150	175	132	63
	D	53	137	117	117*
	E	138	163	132	43

* - by virtue of integrity failure

Test Report	Specimen	Overall width (mm)	Cavity width (mm)	Integrity (mins)	Insulation (mins)
4789067973	A	425	450	135	58
	B	400	450	82	53
	C	134	180	117	68

Test Report	Specimen	Overall width (mm)	Cavity width (mm)	Integrity (mins)	Insulation (mins)
4789225196	A	57	135	135	105
	B	170	220	135	54
	C	412	450	126	60
	D	102	127	135	64

Signed on behalf of Kiwa UK



David Mowatt
Head of IFC Certification /
Kiwa UK

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.
Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.