

Classification Report

Number	26-001561-PR03 (NW-A01-05-en-01)
Owner	fischerwerke GmbH & Co. KG Klaus-Fischer-Str. 1 72178 Waldachtal Germany
Product	Burglar resistant single window
Designation	System: Gealan S 9000 K
Details	Manufacturer Felbermayer Fenster und Türen Erzeugungs-GmbH - Unterwaltersdorf; Material Polyvinylchloride unplasticized (PVC-U) white; Attack side Closing face as per EN 12519; Type of opening Tilt and turn; Installation According to the testing documentation of the attached manufacturer's installation instructions; Overall dimensions (W x H) 1000 mm x 1350 mm; Number of casements 1; Hardware: Manufacturer Mayer & Co. Beschläge GmbH - Salzburg; System Maco Multi matic; window handle Lockable handle; Safety locking points 10; LSG: Class P4A acc. to EN 356; Type iplus top with ipasafe P4A; Manufacturer Interpane
Special features	Fixed with mounting screws 7.5 x 152 mm

Results **)

Burglary resistance according to EN 1627:2021-06



Class: RC 2 / RC 2N

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

Basis *)

EN 1627:2021-06

*) and corresponding national versions (e.g. DIN EN)

Test report 26-001561-PR01 NW-A01-05-en-01

Representation



Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

ift Rosenheim

29.05.2026



Simon Stüer
Deputy Head of Testing Department
Security/Safety Testing



Thomas Zimmer, M.Sc.
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-tested.de
ID: 7A6-03334