



Instytut Techniki Budowlanej

Badania naukowe | Prace rozwojowe | Akredytowany Zespół Laboratoriów |
Jednostka notyfikowana nr 1488 | Członek EOTA | Certyfikowane systemy zarządzania ISO 9001, ISO 27001

CLASSIFICATION No 01605/22/Z00NZM

Customer fischerwerke GmbH & Co. KG

Address Klaus-Fischer-Straße 1
72178 Waldachtal

Product Polyurethane foam
fischer PUP Flex 750 B2

CONSTRUCTION MATERIALS ENGINEERING DEPARTMENT of ITB
having conducted adequate tests, hereby confirms that
polyurethane foam fischer PUP Flex 750 B2 have the following properties:

Range of test		Classification* “fischer PUP Flex 750 B2”	Norm classification
Property	Test method		
Air permeability (1200 Pa)	PN-EN 1026:2001	class 4	PN-EN 12207:2001
Air permability coefficient, α $\text{m}^3/(\text{m} \cdot \text{h} \cdot \text{daPa}^{2/3})$	PN-EN 1026:2001	$\alpha < 0,1$	–
Watertightness	PN-EN 1027:2001 met. 1A	E1200	PN-EN 12208:2001

*Classification relates to gaps of a width of 25 mm, filled with foam on the surface of at least 68 mm

Detailed results of the tests and information about the test sample are included
in Test Report LZM01 06052/16/R41NZM

Person responsible for test:

Head of CONSTRUCTION
MATERIALS ENGINEERING
DEPARTMENT


Magdalena Wasiak MsC, Eng


Ewa Sudoł PhD, Eng

Warsaw, 07/08/2022

This document shall cease to be valid in the event of changing the product components and/or the technology.
Classification is not a marketing authorisation.