

PRESTANDADEKLARATION

DoP 0205

för Upat injektionssystem UPM 33 (Fästdon för användning i delar av murverk)

SV

1. Produkttypens unika identifikationskod: **DoP 0205**
2. Avsedd användning/avsedda användningar: Efterinstallerat fäste i delar av murverk, se bilaga, särskilt bilagor B1- B10.
3. Tillverkare: Upat Vertriebs GmbH, Otto-Hahn Straße 15, 79211 Denzlingen, Tyskland
4. Tillverkarens representant: -
5. System för bedömning och fortlöpande kontroll av prestanda: 1
6. Europeiskt bedömningsdokument: ETAG 029, April 2013, används som EAD
Europeisk teknisk bedömning:
Tekniskt bedömningsorgan:
Anmält/anmälta organ:
ETA-15/0554; 2015-08-27
DIBt- Deutsches Institut für Bautechnik
2873 TU Darmstadt
7. Angiven prestanda:
Mekanisk hållfasthet och stabilitet (BWR 1)
Karakteristiska värden för resistens:
Reduktionsfaktor: Bilagor C6
Karaktäristisk bärformåga hos ett ankare under draglast: Bilagor B2, C1-C4
Karaktäristisk bärformåga hos en förankringsgrupp under draglast: Bilagor C8
Karaktäristisk bärformåga hos ett ankare vid tvärlast: Bilagor B2, C1-C4
Karaktäristisk bärformåga hos en förankringsgrupp med och utan påverkan av kant: Bilagor C8
Karaktäristiskt kantavstånd och inbördes avstånd: Bilagor C7, C8
Minsta kantavstånd och inbördes avstånd: Bilagor C7, C8
Gruppfaktor under drag- och tvärlast: Bilagor C7, C8
Minsta fixturjocklek: Bilagor C7
Varaktighet Bilagor A4, B1, B2
Förflyttningar: Bilagor C5

Säkerhet vid brand (BWR 2)

Reaktion vid brand: Klass (A1)

Hygien, hälsa och miljö (BWR 3)

Innehåll, frisläppning och / eller frisläppning av farliga ämnen: NPD

8. Lämplig teknisk dokumentation och/eller särskild teknisk dokumentation: -

Prestandan för ovanstående produkt överensstämmer med den angivna prestandan. Denna prestandadeklaration har utfärdats i enlighet med förordning (EU) nr 305/2011 på eget ansvar av den tillverkare som anges ovan.

Undertecknad på tillverkarens vägnar av:



Dr. Oliver Geibig, Verkställande direktör affärsenheter och teknik
Tumlingen, 2021-02-15



Jürgen Grün, Verkställande direktör kemi och kvalitet

Denna DoP har förberetts på olika språk. I händelse av tvist om tolkningen ska den engelska versionen alltid råda.

Bilagan innehåller frivilliga och kompletterande information på engelska som överskrider (det specifika språkets) lagkrav.

Specific Part

1 Technical description of the product

The Upat injectionsystem UPM 33 for masonry is a bonded anchor (injection type) consisting of a mortar cartridge with injection mortar Upat UPM 33, UPM 33 Express and UPM 33 Relax, a perforated sieve sleeve and an anchor rod with hexagon nut and washer or an internal threaded rod. The steel elements are made of zinc coated steel, stainless steel or high corrosion resistant steel.

The anchor rod is placed into a drilled hole filled with injection mortar and is anchored via the bond between steel element, injection mortar and masonry and mechanical interlock.

The product description is given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document

The performances given in Section 3 are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The verifications and assessment methods on which this European Technical Assessment is based lead to the assumption of a working life of the anchor of at least 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Mechanical resistance and stability (BWR 1)

Essential characteristic	Performance
Characteristic resistance for tension and shear loads	See Annex C 1 – C 4
Characteristic resistance for bending moments	See Annex C 5
Displacements under shear and tension loads	See Annex C 5
Reduction Factor for job site tests (β -Factor)	See Annex C 6
Edge distances and spacing	See Annex C 7 – C 8

3.2 Safety in case of fire (BWR 2)

Essential characteristic	Performance
Reaction to fire	Anchorages satisfy requirements for Class A1
Resistance to fire	No performance assessed

3.3 Hygiene, health and the environment (BWR 3)

Regarding dangerous substances there may be requirements (e.g. transposed European legislation and national laws, regulations and administrative provisions) applicable to the products falling within the scope of this European Technical Assessment. In order to meet the provisions of Regulation (EU) No 305/2011, these requirements need also to be complied with, when and where they apply.

3.4 Safety in use (BWR 4)

The essential characteristics regarding Safety in use are included under the Basic Works Requirement Mechanical resistance and stability.


4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

In accordance with guideline for European technical approval ETAG 029, April 2013, used as European Assessment Document (EAD) according to Article 66 Paragraph 3 of Regulation (EU) No 305/2011, the applicable European legal act is: [97/177/EC].

The system to be applied is: 1

Installation conditions part 1;


Threaded rods with perforated sleeve UPM SH K; Installation in perforated and solid brick masonry



Pre-positioned installation

UPM SH 12x85 K
UPM SH 16x85 K
UPM SH 16x130 K
UPM SH 20x85 K
UPM SH 20x130 K
UPM SH 20x200 K

Internal threaded anchors UPM-I with perforated sleeve UPM SH K; Installation in perforated and solid brick masonry



Pre-positioned installation

UPM SH 16x85 K – UPM-I M6 and M8
UPM SH 20x85 K - UPM-I M10 and M12

h_{ef} = effective anchorage depth

h_0 = depth of drill hole

t_{fix} = thickness of fixture

h = thickness of masonry

d_0 = nominal drill bit diameter

d_f = diameter of clearance hole in the fixture

$T_{inst,max}$ = maximum torque moment

Upat Injectionsystem UPM 33 for masonry


Product description

Installation condition, part 1: in perforated and solid brick masonry


Annex A 1

Installation conditions part 2:

Threaded rods without perforated sleeve UPM SH K; Installation in solid brick masonry and autoclaved aerated concrete



Internal threaded anchors UPM-I without perforated sleeve UPM SH K; Installation in solid brick masonry and autoclaved aerated concrete



h_{ef} = effective anchorage depth

h_0 = depth of drill hole

t_{fix} = thickness of fixture

h = thickness of masonry

d_0 = nominal drill bit diameter

d_f = diameter of clearance hole in the fixture

$T_{inst,max}$ = maximum torque moment

Upat Injectionsystem UPM 33 for masonry

Product description


Installation condition, part 2: in solid brick masonry and aerated concrete

Annex A 2

Static mixer MR or Static mixer ME



Shuttle cartridge

(sizes: 345 ml; 360 ml; 390 ml; 950 ml; 1100ml; 1500 ml)




Coaxial cartridge

(sizes: 100 ml; 150 ml; 300 ml; 380 ml; 400ml; 410 ml)



2

alternative head geometry



**UPM-I M6, UPM-I M8
UPM-I M10, UPM-I M12**

5

**UPM SH 12x85 K
UPM SH 16x85 K
UPM SH 20x85 K**



6

**UPM SH 16x130 K
UPM SH 20x130 K
UPM SH 20x200 K**

1. Mortar cartridge

4. Hexagon nut

2. Threaded rod

5. Internal threaded anchor UPM-I

3. Washer

6. Perforated sleeve UPM SH K

Upat Injectionsystem UPM 33 for masonry

Product description

Cartridges, anchor rods, internal threaded anchors, perforated sleeves

Annex A 3

Table A1: Materials

Part	Designation	Material		
1	Mortar cartridge	mortar, hardener; filler		
		Steel, zinc plated	Stainless steel A4	High corrosion-resistant steel C
2	Threaded rod	Property class 5.8 or 8.8; EN ISO 898-1:2013 zinc plated $\geq 5\mu\text{m}$, EN ISO 4042:1999 A2K or hot-dip galvanised EN ISO 10684:2004 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8\%$	Property class 50, 70 or 80 EN ISO 3506:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362; 1.4062 EN 10088-1:2014 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8\%$	Property class 50 or 80 EN ISO 3506:2009 or property class 70 with $f_{yk} = 560 \text{ N/mm}^2$ 1.4565; 1.4529 EN 10088-1:2014 $f_{uk} \leq 1000 \text{ N/mm}^2$ $A_5 > 8\%$
3	Washer ISO 7089:2000	zinc plated $\geq 5\mu\text{m}$, EN ISO 4042:1999 A2K or hot-dip galvanised ISO 10684:2004	1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	1.4565; 1.4529 EN 10088-1:2014
4	Hexagon nut	Property class 5 or 8; EN ISO 898-2:2013 zinc plated $\geq 5\mu\text{m}$, ISO 4042:1999 A2K or hot-dip galvanised ISO 10684:2004	Property class 50, 70 or 80 ISO 3506:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	Property class 50, 70 or 80 ISO 3506:2009 1.4565; 1.4529 EN 10088-1:2014
5	Internal threaded anchor UPM I	Property class 5.8; EN 10277-1:2008 zinc plated $\geq 5\mu\text{m}$, EN ISO 4042:1999 A2K	Property class 70 EN ISO 3506:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	Property class 70 EN ISO 3506-1:2009 1.4565; 1.4529 EN 10088-1:2014
	Screw or threaded rod for internal threaded anchor UPM I	Property class 5.8 or 8.8; EN ISO 898-1:2013 zinc plated $\geq 5\mu\text{m}$, ISO 4042:1999 A2K	Property class 70 EN ISO 3506:2009 1.4401; 1.4404; 1.4578; 1.4571; 1.4439; 1.4362 EN 10088-1:2014	Property class 70 EN ISO 3506-1:2009 1.4565; 1.4529 EN 10088-1:2014
6	Perforated sleeve UPM SH K	PP / PE		

Upat Injectionsystem UPM 33 for masonry

Product description
Materials

Annex A 4

Annex 6/24

Specifications of intended use part 1

Anchages subject to:

- Static and quasi-static loads

Base materials:

- Solid brick masonry (Use category b) and autoclaved aerated concrete (Use category d), acc. to Annex B8.
Note: The characteristic resistance is also valid for larger brick sizes and higher compressive strength of the masonry unit.
- Hollow brick masonry (use category c), according to Annex B8
- Mortar strength class of the masonry M2,5 at minimum according to EN 998-2:2010
- For other bricks in solid masonry, hollow or perforated masonry and autoclaved aerated concrete, the characteristic resistance of the anchor may be determined by job site tests according to ETAG 029, Annex B under consideration of the β-factor according to Annex C6, Table C4

Temperature Range:

- I: From - 40°C to +80°C (max. short term temperature +80°C and max. long term temperature +50°C)

Use conditions (Environmental conditions):

- Dry and wet structure (regarding injection mortar)
- Structures subject to dry internal conditions exist
(zinc coated steel, stainless steel or high corrosion resistant steel)
- Structures subject to external atmospheric exposure including industrial and marine environment or exposure to permanently damp internal condition, if no particular aggressive conditions exist
(stainless steel or high corrosion resistant steel)
- Structures subject to external atmospheric exposure and to permanently damp internal condition, if other particular aggressive conditions exist (high corrosion resistant steel)
Note: Particular aggressive conditions are e.g. permanent, alternating immersion in seawater or the splash zone of seawater, chloride atmosphere of indoor swimming pools or atmosphere with extreme chemical pollution (e.g. in desulphurization plants or road tunnels where de-icing materials are used)

Upat Injectionsystem UPM 33 for masonry

Intended Use
Specifications part 1

Annex B 1

Annex 7/24

Specifications of intended use part 2

Design:

- The anchorages have to be designed in accordance with the ETAG 029, Annex C, Design method A under the responsibility of an engineer experienced in anchorages and masonry work
Applies to all bricks, if no other values are specified:
 $N_{Rk} = N_{Rk,s} = N_{Rk,p} = N_{Rk,b} = N_{Rk,pb}$
 $V_{Rk} = V_{Rk,s} = V_{Rk,b} = V_{Rk,c} = V_{Rk,pb}$
- Verifiable calculation notes and drawings have to be prepared taking account the relevant masonry in the region of the anchorage, the loads to be transmitted and their transmission to the supports of the structure. The position of the anchor is indicated on the design drawings

Installation:

- Category d/d: -Installation and use in dry structures
- Category w/w: -Installation and use in dry and wet structures
- Hole drilling by hammer drill mode
- In case of aborted hole: The hole shall be filled with mortar
- Bridging of unbearing layer (e.g. plaster) see Annex B 4 (Table B1.3)
- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site
- Fastening screws or threaded rods (including nut and washer) must comply with the appropriate material and property class of the Upat internal threaded anchor UPM I
- minimum curing time see Annex B5. Table B3
- Commercial standard threaded rods, washers and hexagon nuts may also be used if the following requirements are fulfilled:

Material dimensions and mechanical properties of the metal parts according to the specifications are given in Annex A4, Table A1

Conformation of material and mechanical properties of the metal parts by inspection certificate 3.1 according to EN 10204:2004, the documents shall be stored


Marking of the threaded rod with the envisaged embedment depth. This may be done by the manufacturer of the rod or by a person on job site

Upat Injectionsystem UPM 33 for masonry

Intended Use
Specifications part 2

Annex B 2

Annex 8/24



Marking:

Property class 8.8 or high corrosion-resistant steel C, property class 80: •

Stainless steel A4, property class 50 and high corrosion-resistant steel C, property class 50: ••


Table B1.1: Installation parameters for threaded rod without perforated sleeve

Size		M8	M10	M12
Nominal drill hole diameter	$d_{\text{nom}} = d_0$ [mm]	10	12	14
Width across flat	SW [mm]	13	17	19
Effective anchorage depth ¹⁾	$h_{\text{ef},\text{min}}$ [mm]	50		
Depth of drill hole $h_0 = h_{\text{ef}}$	$h_{\text{ef},\text{max}}$ [mm]	h-30 and ≤ 200 mm		
Effective anchorage depth AAC	$h_{\text{ef},\text{min}}$ [mm]	100		
	$h_{\text{ef},\text{max}}$ [mm]	120		
Maximum torque moment	$T_{\text{inst},\text{max}}$ [Nm]	10		
Max. torque moment for autoclaved aerated concrete	$T_{\text{inst},\text{max}}$ [Nm]	1	2	
Diameter of clearance hole in the fixture	Pre-position anchorage $d_f \leq$ [mm]	9	12	14
	Push through anchorage $d_f \leq$ [mm]	11	14	16

¹⁾ $h_{\text{ef},\text{min}} \leq h_{\text{ef}} \leq h_{\text{ef},\text{max}}$ is possible.

Upat internal threaded anchor UPM-I

UPM-I M6, UPM-I M8



Marking: size, e.g. M8
stainless steel A4: e.g. M8 A4
high corrosion-resistant steel C: e.g. M8 C

UPM-I M10, UPM-I M12




Table B1.2: Installation parameters for internal threaded anchor UPM-I without perforated sleeve

Size UPM I	M6	M8	M10	M12
diameter of internal threaded anchor d_H [mm]	11		15	
Nominal drill hole diameter $d_{\text{nom}} = d_0$ [mm]	14		18	
Depth of drill hole h_0 [mm]			85	
Effective anchorage depth $L_H = h_{\text{ef}}$ [mm]			85	
Maximum torque moment $T_{\text{inst},\text{max}}$ [Nm]	4		10	
Max. torque moment for autoclaved aerated concrete $T_{\text{inst},\text{max}}$ [Nm]		1		2
Diameter of clearance hole in the fixture $d_f \leq$ [mm]	7	9	12	14
Screw-in depth $L_{E,\text{min}}$ [mm]	6	8	10	12

Upat Injectionsystem UPM 33 for masonry

Intended Use

Installation parameters, part 1

Annex B 3

Perforated sleeves UPM SH 12x85; 16x85; 16x130; 20x85; 20x130; 20x200 K

Marking: size
 $D_{\text{Sleeve}} \times L_{\text{Sleeve}}$
e.g. 16x85





Table B1.3: Installation parameters (threaded rod and internal threaded anchor with perforated sleeve; only pre-positioned anchorage)

Size UPM SH...K	12x85	16x85	16x130 ²⁾	20x85	20x130 ²⁾	20x200 ²⁾
Nominal drill hole diameter ($d_0 = D_{\text{Sleeve}}$)	$d_{\text{nom}} = d_0$ [mm]	12	16	20		
Depth of drill hole	h_0 [mm]	90	90	135	90	135
Effective anchorage depth ¹⁾	$h_{\text{ef},\text{min}}$ [mm]	85	85	110	85	110
	$h_{\text{ef},\text{max}}$ [mm]	85	85	130	85	130
Size of threaded rod	[-]	M8	M8, M10		M12	
Size of internal threaded anchor	[-]	---	11x85	---	15x85	---
Maximum torque moment threaded rod and internal threaded anchor	$T_{\text{inst,max}}$ [mm]			2		

¹⁾ $h_{\text{ef},\text{min}} \leq h_{\text{ef}} \leq h_{\text{ef},\text{max}}$ is possible.

²⁾ Bridging of unbearing layer (e.g. plaster) possible

Steel brush BS



Only for solid bricks and aerated concrete

Table B2: Parameters of steel brush

Drill hole diameter	d_0 [mm]	10	12	14	16	18	20
Brush diameter	$d_{b,nom}$ [mm]	11	14	16	20	20	25

Table B3: Maximum processing time of the mortar and minimum curing time

(During the curing time of the mortar the masonry temperature may not fall below the listed minimum temperature).

Temperature at anchoring base [°C]	Minimum curing time ¹⁾ t_{cure} [minutes]			System-temperature (mortar) [°C]	Maximum processing time t_{work} [minutes]		
	UPM 33 Express ³⁾	UPM 33 ²⁾	UPM 33 Relax ²⁾		UPM 33 Express ³⁾	UPM 33 ²⁾	UPM 33 Relax ²⁾
-10 to -5	12 hours						
>-5 to ±0	3 hours	24 hours					
>±0 to +5	90	3 hours	6 hours				
>+5 to +10	45	90	3 hours				
>+10 to +20	30	60	2 hours				
>+20 to +30		45	60				
>+30 to +40		35	30				
				±0	5		
				+5	5	13	20
				+10	3	9	20
				+20	1	5	10
				+30		4	6
				+40		2	4

¹⁾ For wet bricks the curing time must be doubled

²⁾ Minimum cartridge temperature +5°C

³⁾ Minimum cartridge temperature ±0°C

Upat Injectionsystem UPM 33 for masonry

Intended Use

Steel brush








Processing times and curing times

Annex B 5

Annex 11/24

Installation instructions part 1








Installation and Preparing the cartridge in solid brick and autoclaved aerated concrete (without perforated sleeve)

1		Drill the hole. Depth of drill hole h_0 and drill hole diameter d_0 see Table B1.1 or B1.2
2		Blow out the drill hole two times by hand. Brush the drill hole two times using an adequate steel brush (see Table B2) and blow out two times again
3		Remove the sealing cap
4		Screw on the static mixer (the spiral in the static mixer must be clearly visible)
5		Place the cartridge into a suitable dispenser.
5	Fill approximately 2/3 of the drill hole with mortar Always begin from the bottom of the hole to eliminate voids ¹⁾ .	Press out approximately 10 cm of material until the mortar is permanently grey in colour. Mortar which is not grey in colour will not cure and must be disposed off.
6		For push through installation (not UPM-I) fill the annular gap also with mortar.
7		Wait for the specified curing time t_{cure} see Table B3
7		Mounting the fixture $T_{inst,max}$ see Table B1.1 or B1.2

¹⁾ For the exact quantity of mortar see manufacturer's specification.

















Installation instructions part 2

Installation in perforated or solid brick with perforated sleeve (pre-positioned anchorage)

1		Drill the hole. Depth of drill hole h_0 and drill hole diameter d_0 see Table B1.3	When install perforated sleeves in solid bricks or solid areas of hollow bricks, also clean the hole by blowing out and brushing	
2		Remove the sealing cap		Screw on the static mixer (the spiral in the static mixer must be clearly visible)
3		Place the cartridge into a suitable dispenser		Press out approximately 10 cm of material until the mortar is permanent-ly grey in colour. Mortar which is not grey in colour will not cure and must be disposed off
4		Insert the perforated sleeve flush with the surface of the masonry or plaster.		Fill the perforated sleeve completely with mortar beginning from the bottom of the hole ¹⁾ .
5		Only use clean and oil-free anchor elements. Mark the threaded rod for setting depth. Insert the threaded rod or the internal threaded anchor UPM-I by hand using light turning motions until reaching the setting depth marking (threaded rod) or flush with the surface (internal threaded anchor).		
6		Wait for the specified curing time t_{cure} see Table B3		Mounting the fixture. $T_{inst,max}$ see Table B1.3

¹⁾ For the exact quantity of mortar see manufacturer's specification.

Table B 4: Summary of bricks and blocks

Brick No. 1 Solid brick Mz according to EN 771-2 $\rho \geq 1,8$ [kg/dm ³] $fb \geq 10$ or 20 [N/mm ²]			Brick No. 6 Perforated brick HLz according to EN 771-1 $\rho \geq 1,4$ [kg/dm ³] $fb \geq 20$ [N/mm ²]		
Brick No. 2 Solid sand-lime brick according to EN 771-2 $\rho \geq 1,8$ [kg/dm ³] $fb \geq 10$ or 20 [N/mm ²]			Brick No. 7 Perforated brick HLz according to EN 771-1 $\rho \geq 1,0$ [kg/dm ³] $fb \geq 10$ [N/mm ²]		
Brick No. 3 Solid sand-lime brick according to EN 771-2 $\rho \geq 1,8$ [kg/dm ³] $fb \geq 10$ or 20 [N/mm ²]			Brick No. 8 Perforated brick HLz filled with mineral wool according to EN 771-1 $\rho \geq 0,6$ [kg/dm ³] $fb \geq 8$ [N/mm ²]		
Brick No. 4 Sand-lime hollow brick according to EN 771-2 $\rho \geq 1,4$ [kg/dm ³] $fb \geq 12$ or 20 [N/mm ²]			Brick-No. 9 Light-weight con- crete hollow block Hbl according to EN 771-1 $\rho \geq 1,0$ [kg/dm ³] $fb \geq 4$ [N/mm ²]		
Brick No. 5 Perforated brick HLz according to EN 771-1 $\rho \geq 0,9$ [kg/dm ³] $fb \geq 10$ [N/mm ²]			Brick No. 10 Autoclaved aerated concrete block $\rho \geq 350, 500$ or 650 [kg/dm ³] $fb \geq 2, 4$ or 6 [N/mm ²]		







Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry

Intended Use
Types and dimensions of blocks and bricks

Annex B 8

Table B5.1: Allocation of anchor rods¹⁾, perforated sleeves^{1,2)} and perforated or solid bricks

Kind of masonry	Brick	Valid anchor rods and perforated sleeves	
Brick No. 1 Solid brick Mz according to EN 771-2 $\rho \geq 1,8 \text{ [kg/dm}^3\text{]}$ $fb \geq 10 \text{ or } 20 \text{ [N/mm}^2\text{]}$		 	M8; M10; M12 UPM-I M6, M8
Brick No. 2 Solid sand-lime brick according to EN 771-2 $\rho \geq 1,8 \text{ [kg/dm}^3\text{]}$ $fb \geq 10 \text{ or } 20 \text{ [N/mm}^2\text{]}$		 	M8; M10; M12 UPM-I M6, M8
Brick No. 3 Solid sand-lime brick according to EN 771-2 $\rho \geq 1,8 \text{ [kg/dm}^3\text{]}$ $fb \geq 10 \text{ or } 20 \text{ [N/mm}^2\text{]}$		 	UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 16x130 K UPM SH 20x130 K
Brick No. 4 Sand-lime hollow brick according to EN 771-2 $\rho \geq 1,4 \text{ [kg/dm}^3\text{]}$ $fb \geq 12 \text{ or } 20 \text{ [N/mm}^2\text{]}$		 	UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 16x130 K UPM SH 20x130 K
Brick No. 5 Perforated brick HLz according to EN 771-1 $\rho \geq 0,9 \text{ [kg/dm}^3\text{]}$ $fb \geq 10 \text{ [N/mm}^2\text{]}$		 	UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 16x130 K UPM SH 20x130 K
Brick No. 6 Perforated brick HLz according to EN 771-1 $\rho \geq 1,4 \text{ [kg/dm}^3\text{]}$ $fb \geq 20 \text{ [N/mm}^2\text{]}$		 	UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K

¹⁾ Other combinations can be used after job site tests acc. to ETAG 029, Annex B.

²⁾ Sleeve/anchor rod combination see table B1.3

The β - factor for this job site tests are given in Table C4

Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry

Intended Use

Allocation of anchor rods, perforated sleeves and bricks, part 1

Annex B 9

Table B5.2: Allocation of anchor rods¹⁾, perforated sleeves^{1,2)} and perforated or solid bricks

Kind of masonry	Brick	Valid anchor rods and perforated sleeves	
Brick No. 7 Perforated brick HLz according to EN 771-1 $\rho \geq 1,0$ [kg/dm ³] $fb \geq 10$ [N/mm ²]			UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 20x130 K
Brick No. 8 Perforated brick HLz filled with mineral wool according to EN 771-1 $\rho \geq 0,6$ [kg/dm ³] $fb \geq 8$ [N/mm ²]			UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 16x130 K UPM SH 20x130 K UPM SH 20x200 K
Brick-No. 9 Light-weight con- crete hollow block Hbl according to EN 771-1 $\rho \geq 1,0$ [kg/dm ³] $fb \geq 4$ [N/mm ²]			UPM SH 12x85 K UPM SH 16x85 K UPM SH 20x85 K UPM SH 16x130 K UPM SH 20x130 K
Brick No. 10 Autoclaved aerated concrete block $\rho \geq 350, 500$ or 650 [kg/dm ³] $fb \geq 2, 4$ or 6 [N/mm ²]			M8; M10; M12 UPM-I M6 UPM-I M8 UPM-I M10 UPM-I M12




¹⁾ Other combinations can be used after job site tests acc. to ETAG 029, Annex B.

²⁾ Sleeve/anchor rod combination see table B1.3

The β - factor for this job site tests are given in Table C4

Imaging of the bricks are not scaled

Table C1.1: Characteristic values of resistance under tension loads and under shear loads

Brick	Density ρ [kg/dm ³] - Compressive strength f_b [N/mm ²]	Perforated sleeve UPM SH...K	Anchor size or screw size in internal threaded anchor	Effective anchorage depth $h_{ef,min}$ [mm] $h_{ef,max}$ [mm]	Characteristic resistance [kN]	
					N_{Rk}	V_{Rk}
					Temp. 50/80°C	All categories
 No.1 Solid brick Mz	$\rho \geq 1,8$ $f_b \geq 10$	without	M8	50 200	4,0	2,5
			M10	50 79	3,5	2,0
			M10	80 199	5,0	3,0
			M10	200 200	8,5	7,5
			M12	50 79	3,0	2,0
			M12	80 199	5,5	3,5
			M12	200 200	8,0	5,0
			UPM-I M6/ M8	85 85	5,5	2,5
			M8	50 200	5,5	4,0
 No.2 Solid sand-lime brick	$\rho \geq 1,8$ $f_b \geq 10$	without	M10	50 79	5,0	3,0
			M10	80 199	7,0	4,5
			M10	200 200	8,5	8,5
			M12	50 79	4,5	3,0
			M12	80 199	8,0	5,0
			M12	200 200	8,5	7,0
			UPM-I M6/ M8	85 85	8,0	5,0
			M8	50 200	2,5	1,5
			M10	50 79	8,5	6,0
 No.1 Solid brick Mz	$\rho \geq 1,8$ $f_b \geq 20$	without	M10	80 199	2,5	1,5
			M12	200 200	8,5	6,5
			UPM-I M6/ M8	85 85	2,5	1,5
			M8	50 200	3,5	2,0
			M10	50 79	8,5	8,5
			M10	80 199	3,5	2,0
	$\rho \geq 1,8$ $f_b \geq 20$	with	M10	200 200	8,5	8,5
			M12	50 79	3,5	2,0
			M12	80 199	8,5	8,5
			M12	200 200	8,5	8,5
			UPM-I M6/ M8	85 85	3,5	2,0
			M8	50 200	4,0	4,0

Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry



Performances

Characteristic values of resistance under tension loads and under shear loads, part 1

Annex C 1

Annex 17/24

Table C1.2: Characteristic values of resistance under tension loads and under shear loads

Brick	Density ρ [kg/dm ³] - Compressive strength f_b [N/mm ²]	Perforated sleeve UPM SH...K	Anchor size or screw size in internal threaded anchor	Effective anchorage depth $h_{ref,min}$ [mm] $h_{ref,max}$ [mm]	Characteristic resistance [kN]		All categories
					N_{Rk}	V_{Rk}	
					Temp. 50/80°C		
					d/d	w/w	
 No.3 Solid sand-lime brick	$\rho \geq 1,8$ $f_b \geq 10$	12x85 16x85 16x85 20x85 16x130 20x130	M8 UPM-I M6 M8/M10, UPM-I M8 M12, UPM-I M10/M12 M8/M10 M12	85 85 85 85 110 110	85 85 85 85 130 130	6,0 3,5 3,5 8,5 3,5 7,0	3,0
			3,5				
			4,5				
			5,5				
			5,5				
			6,0				
 No.4 Sand-lime hollow brick	$\rho \geq 1,4$ $f_b \geq 12$	12x85 16x85 16x85 20x85 16x130 20x130	M8 UPM-I M6 M8/M10, UPM-I M8 M12, UPM-I M10/M12 M8/M10 M12	85 85 85 85 110 110	85 85 85 85 130 130	2,5 3,0 3,0 3,0 3,0 3,0	2,5
			4,5				
			4,5				
			4,5				
			4,5				
			4,5				
	$\rho \geq 1,4$ $f_b \geq 20$	12x85 16x85 16x85 20x85 16x130 20x130	M8 UPM-I M6 M8/M10, UPM-I M8 M12, UPM-I M10/M12 M8/M10 M12	85 85 85 85 110 110	85 85 85 85 130 130	4,5 5,0 5,0 5,0 5,5 5,5	4,0
			4,0				
			7,5				
			7,5				
			7,5				
			7,5				

Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry






Performances

Characteristic values of resistance under tension loads and under shear loads, part 2

Annex C 2

Annex 18/24

Table C1.3: Characteristic values of resistance under tension loads and under shear loads

Brick	Density ρ [kg/dm ³] - Compressive strength f_b [N/mm ²]	Perforated sleeve UPM SH...K	Anchor size or screw size in internal threaded anchor	Effective anchorage depth $h_{ef,min}$ [mm] $h_{ef,max}$ [mm]	Characteristic resistance [kN]			
					All categories			
					N_{Rk}	V_{Rk}		
 No.5 Perforated brick HLz	$\rho \geq 0,9$ $f_b \geq 10$		12x85	M8	85	85	4,0 3,5 4,0	
			16x85	UPM-I M6	85	85	3,5 3,5 4,0	
			16x85	M8/M10, UPM-I M8	85	85	3,5 3,5 5,5	
			20x85	M12, UPM-I M10/M12	85	85	5,0 4,5 6,0	
			16x130	M8/M10	130	130	5,0 4,5 5,5	
			20x130	M12	110	130	5,0 4,5 6,0	
 No.6 Perforated brick HLz	$\rho \geq 1,4$ $f_b \geq 20$		12x85	M8	85	85	4,0 3,5 7,5 (5,5) ¹⁾	
			16x85	UPM-I M6	85	85	2,5 4,0	
			16x85	M8/M10, UPM-I M8	85	85	2,5 4,5	
			20x85	M12, UPM-I M10/M12	85	85	3,0 8,5 (5,5) ¹⁾	
 No.7 Perforated brick HLz	$\rho \geq 1,0$ $f_b \geq 10$		12x85	M8	85	85	0,9	
			16x85	M8/M10, UPM-I M6/M8	85	85	2,5	1,2
			20x85	M12, UPM-I M10/M12	85	85		
			16x130	M8/M10	110	130	3,5 3,0	1,5
			20x130	M12	110	130		
 No.8 Perforated brick HLz	$\rho \geq 0,6$ $f_b \geq 8$		12x85	M8	85	85	2,0 2,0 2,5	
			16x85	UPM-I M6	85	85	2,0 1,5 2,5	
			16x85	M8/M10, UPM-I M8	85	85	2,0 1,5 3,0	
			20x85	M12, UPM-I M10/M12	85	85	2,0 2,0 1,5	
			16x130	M8/M10	130	130	3,0 2,5 3,0	
			20x130	M12	110	130	2,0 2,0 1,5	
			20x200	M12	180	200	3,0 3,0 1,5	
 No.9 Light-weight concrete hollow block	$\rho \geq 1,0$ $f_b \geq 4$		12x85	M8	85	85	3,0	2,0
			16x85	M8/M10, UPM-I M6/M8	85	85		
			20x85	M12, UPM-I M10/M12	85	85		
			16x130	M8/M10	130	130		
			20x130	M12	110	130		

¹⁾ Characteristic value of pushing out of one brick $V_{Rk,pb} = 5,5$ kN

Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry


Performances

Characteristic values of resistance under tension loads and under shear loads, part 3

Annex C 3

Annex 19/24

Table C1.4: Characteristic values of resistance under tension loads and under shear loads

Brick	Density ρ [kg/dm ³] - Compressive strength f_b [N/mm ²]	Perforated sleeve UPM SH...K	Anchor size or screw size in internal threaded anchor	Effective anchorage depth $h_{ef,min}$ [mm] $h_{ef,max}$ [mm]	Characteristic resistance [kN]	
					N_{Rk}	V_{Rk}
					Temp. 50/80°C	
	$\rho \geq 350$ $f_b \geq 2$	ohne	M8	100	120	1,2
			M10	100	120	
			M12	100	120	
			UPM-I M6/M8 UPM-I M10/M12	85		
	$\rho \geq 500$ $f_b \geq 4$	ohne	M8	100	120	2,0
			M10	100	120	2,5
			M12	100	120	
			UPM-I M6/M8 UPM-I M10/M12	85		2,0
	$\rho \geq 650$ $f_b \geq 6$	ohne	M8	100	120	3,0
			M10	100	120	5,0
			M12	100	120	
			UPM-I M6/M8 UPM-I M10/M12	85		3,5

Imaging of the bricks are not scaled

Upat Injectionsystem UPM 33 for masonry

Performances

Characteristic values of resistance under tension loads and under shear loads, part 4

Annex C 4

Annex 20/24

Table C2: Characteristic bending moments

Größe			M8	M10	M12
Characteristic bending moment $M_{Rk,s}$	Zinc-plated steel	Property class	5.8 [Nm]	19	37
			8.8 [Nm]	30	60
	Stainless steel A4	Property class	50 [Nm]	19	37
			70 [Nm]	26	52
			80 [Nm]	30	60
	High corrosion-resistant steel C	Property class	50 [Nm]	19	37
			70 ¹⁾ [Nm]	26	52
			80 [Nm]	30	60

¹⁾ $f_{uk} = 700 \text{ N/mm}^2$; $f_y = 560 \text{ N/mm}^2$

Table C2.1: Characteristic bending moments for internal threaded anchors UPM I

Size UPM I			M6	M8	M10	M12
Characteristic bending moments $M_{Rk,s}$	zinc plated steel,	Property class of screw	5.8 [Nm]	8	19	37
			8.8 [Nm]	12	30	60
	stainless steel A4	Property class of screw	70 [Nm]	11	26	52
	high corrosion resistant steel C	Property class of screw	70 [Nm]	11	26	52

Tabelle C3: Displacements under tension loads and shear loads

Material	N [kN]	δN_0 [mm]	δN_∞ [mm]	V [kN]	δV_0 [mm]	δV_∞ [mm]
	$\frac{N_{Rk}}{1,4 * \gamma_M}$	0,03	0,06	$\frac{V_{Rk}}{1,4 * \gamma_M}$	0,59	0,88
solid units and autoclaved aerated concrete	$\frac{N_{Rk}}{1,4 * \gamma_M}$	0,03	0,06	$\frac{V_{Rk}}{1,4 * \gamma_M}$	1,71	2,56
	$\frac{N_{Rk}}{1,4 * \gamma_M}$	0,03	0,06	$\frac{V_{Rk}}{1,4 * \gamma_M}$	1,71	2,56
hollow units	$\frac{N_{Rk}}{1,4 * \gamma_M}$	0,03	0,06	$\frac{V_{Rk}}{1,4 * \gamma_M}$	1,71	2,56
	$\frac{N_{Rk}}{1,4 * \gamma_M}$	0,03	0,06	$\frac{V_{Rk}}{1,4 * \gamma_M}$	1,71	2,56

Upat Injectionsystem UPM 33 for masonry

Performances

Characteristic bending moments; displacements

Annex C 5

Annex 21/24

Table C4: β- factor for job site tests according to ETAG 029, Annex B

Using categories		w/w	d/d
Temperature range [°C]		50/80	50/80
Brick	Size ¹⁾		
Solid brick	M8	0,57	0,96
	M10	0,59	
	M12 UPM I 11x85 UPM I 15x85	0,60	
Hollow brick	All sizes	0,86	0,96
Autoclaved aerated concrete	All size	0,73	0,81

Upat Injectionsystem UPM 33 for masonry**Performances**
β- factors for job site tests**Annex C 6**

Annex 22/24

Table C5: Edge distance and spacing (installation with and without sleeves)

Direction to bed joint			⊥				Group factor				Min. thickness of the masonry members [mm]	
Brick No.	h_{ef} [mm]	$c_{cr} = c_{min}$	s_{min}	s_{cr}	s_{min}	s_{cr}	⊥					
		[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	$\alpha_{g,N}$	$\alpha_{g,V}$	$\alpha_{g,N}$	$\alpha_{g,V}$	
1	50	100	75	60 ¹⁾	150	2	2	1,5	1,4			$h_{ef} + 30$ (≥ 80)
	80	100	75	60 ¹⁾	240	2	2	1,5	1,4			
	200	150	75		240			2				
2	50	100	75		240			2				
	80	100	75		240			2				
	200	150	75		240			2				
3	85	100	115		240			2				
	130	100	115		240			2				
4	all sizes	100	115	100	240	2	2	1,5	1,5			
5	all sizes	100	115		240			2				
6	all sizes	100	115		240			2				
7	all sizes	100	100	240	100	375 (500) ²⁾	1	1	1	1		
8	all sizes	120	245			250			2			
9	all sizes	80	240			365			2			
10	all sizes	100	250			300			2			

¹⁾ only valid for tension loads, for shear loads $s_{min} \parallel = s_{cr} \parallel$

²⁾ spacing depending on brick dimension, brick dimension see table B4, brick 7


Upat Injectionsystem UPM 33 for masonry

Performances

Edge distance and spacing

Annex C 7

Annex 23/24



* Only, if joints are visible and vertical joints are not filled with mortar

$s_{min \parallel}$ = Minimum spacing parallel to bed joint

$s_{min \perp}$ = Minimum spacing vertical to bed joint

$s_{cr \parallel}$ = Characteristic spacing parallel to bed joint

$s_{cr \perp}$ = Characteristic spacing vertical to bed joint

$c_{cr} = c_{min}$ = Edge distance

$\alpha_{g,N \parallel}$ = Group factor for tension load parallel to bed joint

$\alpha_{g,V \parallel}$ = Group factor for shear load parallel to bed joint

$\alpha_{g,N \perp}$ = Group factor for tension load vertical to bed joint

$\alpha_{g,V \perp}$ = Group factor for shear load vertical to bed joint

For $s > s_{cr}$ $\alpha_g = 2$

For $s_{min} \leq s \leq s_{cr}$ α_g according to table C5

$$N_{Rk}^g = \alpha_{g,N} \cdot N_{Rk}; \quad V_{Rk}^g = \alpha_{g,V} \cdot V_{Rk} \quad (\text{Group of 2 anchors})$$

$$N_{Rk}^g = \alpha_{g,N \parallel} \cdot \alpha_{g,N \perp} \cdot N_{Rk}; \quad V_{Rk}^g = \alpha_{g,V \parallel} \cdot \alpha_{g,V \perp} \cdot V_{Rk} \quad (\text{Group of 4 anchors})$$

Upat Injectionsystem UPM 33 for masonry

Performance

Definition of minimum edge distance, minimum spacing and group factors

Annex C 8